App. F. IX-4

1927

File No. 95-27

Previous References (ged)

ged 29-26-(1-3)
" 163-22-(1-9, 94, 12, 14-16)

Serial Nos. ~~1-11~~ 1, 5-11

Later References

ged 12-31 (5-6)

preserve

(57)

General and Revenue Secretariat.

Serial Nos.

Part B for May 1929

SUBJECT

Amendments to the Petroleum Rules and revision of Form A of the Petroleum Rules

---

Be 23.5.29

G. R. S. APP F.III—1] 1927-1928

GENERAL AND REVENUE SECRETARIAT.

(Genl)

NOTES.

File No. 95-27

FILE HEADING.

Introduction of a new Licence form for the possession of kerosene petroleum referred to in rule 6, chap. IV-pt II of the Petroleum Rules - in one or more receptacles

FROM

The Dir of Ins

No. C 1488/27 Dated 23-7-28 Received

Diary No. 6110	Enclos. 3 Spare copies	Serial No. 1

BRIEF ABSTRACT OF LETTER.

Recommends the introduction of a new form and requests that he may be empowered to issue such special licences

NOTES AND ORDERS.

The rules for the issue of special licences for the possession of kerosene petroleum in receptacles containing more than 6 5 gallons but not more than 2 000 gallons each were framed (Rule 6. chap. IV - part II), two form

NOTES—First Sheet.

6110

App. F. III—2]

General and Revenue Secretariat. Genl File No. 95 of 1927

Serial No.

for the issue of licences was introduced then

2) on a reference from the Dir. of I.C. on this point, a new form 'Q' was introduced in G.O. No. I.C. 2118-27/Genl. 29-26-2 of 28.9.26 and the Dir. was empowered to issue licences himself in cases where the capacity of each storage tanks does not exceed 5000 gallons. (no. I.C. 2128-36 of 28.9.26)

3) the present case from the Burma Storage Co. is for a special licence to store 10,000 gallons under the same rule (Rule 6, cl. IV - part II). As the form Q introduced in G.O. dated 28.9.26 does not suit the purpose, the capacity of the tank erected by them being 10,000 gallons, the Dir., after consultation with the Chief Insp. of Explosives in India suggests a new form ~~abstract~~ similar to form 'Q' (with additions indicated by him).

4) the opinion of the Law Secy. as in all previous cases, seems

Passed B/F 24-7-26

NOTE—Contn. sheet

General and Revenue Secretariat. Genl File No. 95 of 1927.

Serial No.

necessary.

5) In regard to the issue of Petroleum licenses the Dir. has been empowered in certain cases detailed in para 2 - pages 2 in Genl. 29.9.26 and S.O. dated 28.9.26.

6) Points for orders: -

1) Whether the Dir. should bring issue such licenses irrespective of the capacity of the storage receptacle, or the quantity to be refined.

d) 1) It does not seem necessary to raise the present limit of 500 gallons.

+(2) Whether the form proposed to be introduced should be number R so as form 'R' or 'Q 2' + in the latter case the existing form will have to be 'Q 1'

q) 2). The form proposed may be introduced.

7) For orders.

31/1/28 (Sd/ D) 1/2

10) 1. I think the Dir may himself issue such licenses, after taking the opinion of the Chief Inspecting Explosives

11) 2. The form seems suitable

12) Law Dept with complete for form of opinion as to the suitableness of the form. I think the rule will also have to be amended so as to remove the limit of 2000 gallons

3 2 28

4/2

8/2

NOTE—Contn. sheet

WD 0324—GPB—60,000—21-5-27

4040/27 6110 4

App. F. III—2]

General and Revenue Secretariat. Sec. File No. 95 of 1927

Serial No.

13) The form seems suitable.

14) Rule 6 has to be amended

Draft put with Comptt

8/12/27

15) Registration of notes on the 2nd December hearing

16/2/28

16) Rejected

17/2/28

18/2/28

FEB. 1928
4630

Resolve U.P.

NOTE—Contn. sheet.

WD 0324—GPB—60,000—24-5-27

General and Revenue Secretariat. Genl File No. 9 S of 1927.

Serial No.

17) Two drafts and a notification amending last Rule are put up for approval.

18) Copies of the Burma Petroleum Regulation and Rules are put up.

19) The Protection branch may perhaps also be consulted

Prot. Br) 24/3

20) Please put up the Bombay & Madras Petroleum Rules.

29/3

21) The Burma Petroleum Act (with notes thereunder) is hereunto put up

22) The Bombay & the Madras Rules are to be found at pages 61 & 93 of the Book.

23) The amendment of Rule 6 proposed in the draft notification is within the rule-making powers of Govt. under the Petroleum Regulation. It would be better to refer also to the British Indian Rules to which the Chief Inspector, Calcutta, has drawn attention and see whether the proposed amendment is in accordance with it. No up-to-date copy of the Burmese Rules is available in the Pro. Br.

Secy) 31/3

24) A. may be sent for

7-4-27

NOTE—Contn. sheet

WD 0321—GPB—60,000—21-5-27

General and Revenue Secretariat. Genl. File No. 95 of 1927.

Serial No.	
25)	File may be sent to the Library for timely placing an order immediately for Complete up-to-date rules & for requesting early supply thereof. 9/4/28
26)	To the Library for necessary action. Asst 9/4
27)	Action has been taken separately. The file is returned to Pro. Br. S.O. 9/4/28 Extracts taken & action forwarded separately. AG 10.4.28
28)	The receipt of up-to-date rules may perhaps be awaited from 18.4.28 Asst 19/4 to 19/4
29)	Copy of Rules issued by the Govt of Bengal under the Indian Petroleum Act, 1899 have been received. The same is hereunto put up & kind attn is invited to paras 23 & 24. The rule refd to by

Put up a copy. S.O. 9/4/28

Action taken. AG 10.4.28

Left. A Asst. 9/4

NOTE—Contn. sheet

General and Revenue Secretariat. Ext. File No. 95 of 1927.

Serial No.

Chief Inspector of Explosives Calcutta is at Flag B. His rule here (Flag 5) is almost the same with this exception that our rule gives a maximum.

30) Ruled for orders
Done
4/8/28
6/8

31) The expression "Stored in bulk" used in Rule 6 as proposed to be revised does not appear to be appropriate. As defined in the Rules "petroleum in bulk" means petroleum in quantities exceeding 500 gallons contained in any one receptacle, while the object in view is to make Rule 6 applicable to any quantity of petroleum exceeding 65 gallons. All that seems necessary to secure this object is to omit the words "but not more than 2000 gallons" Cf the Corresponding Bengal Rule

Seen
Sent with Comps
3/8

32) Seen
8/8
15/8

33) Please show the G.O. & rule (as revised) & the Secy L. Br
16/8

18/8/28
16/8

34) Seen
8/8/28.

NOTE.—Contn. sheet

COM. & DEV. DEPARTMENT
DEVELOPMENT BRANCH

WD 0321—GPB—60,000—24-5-27

6"·9-2)

8

App. F. III—2]

General and Revenue Secretariat. Ecl. File No. 95 of 1927

Serial No.

35) Ref[d] Para 33 (and Para 34) - The L.R has no remarks to offer on the offr Sub[n] for appl[n]

Sec[y] D)

WP
25/8

FD
28 AUG. 1928
No. 1415

36) (1st Member)

WP
28.8.28

WP
28/8

37) Why should there be two forms of licences issued under one Rule — No 6 of Chap IV? Are there two forms in use in British India. When the Max[m] limit is removed from the rule one form may suffice, the fee to be charged being different in the different cases according to the quantity to be stored. The British Indian practice in this respect may be referred to and the drafts suitably revised

Mudy
29.8.28

WP
31.8.28

WP
31/8

NOTE—Contn. sheet

6110-27

I.D. Pt. 1

9

App. F. III—2]

General and Revenue Secretariat. Econ File No. 95 of 1927

Serial No.	
1	38) Consultations of the Law Sects. deem necessary on the several points raised by the Members in the Minutes above 39) for orders.
	40) Yes. 41) In the meanwhile please also make a reference to the Dir of Sec in the matter WD 5/9
	42) Note submitted as directed in para 41 WD 5-9-28
	43) Please move a send to the Prot Br WD 5/9/28.
2	To the Nr. of Ste No D. 2801 & 5-9-28 calls for certain information in the matter of the introduction of the new forms suggested in SC (1)
	Protection Br. 44) may be sent to this Branch after the Director's reply is received WD 6/9
6	From the Dir of Ste No. C_2-1488/27-28 & 20.11.28 Submitted for consideration

GEN. & REV. SECRETARIAT
6 SEP 1928
DEVELOPMENT BRANCH

Issued.

NOTE—Contn. Sheet.

WD 01714—GPB—30,000—18-4-28

224/pet 4036

App. F. III—2]

General and Revenue Secretariat. Genl File No. 95 of 1927

Serial No.

Certain amendments to rule 6 chap. IV - part 2. of the Mysore Petroleum Rules.

45) Refer:- Paras 3 & 4 of Notes - D.Q. Proc. Br.)

26/11/28 (S.R. 26/11/28 Protn. Br.)

46) Refer para 31.. The Director is also of the same opinion. His suggestions may be adopted.

Law Secy) 29/11

47) Yes 29.11

48) Secy. Legl) 29/11

49) Submd. for orders Refer:- Para 43

29.11.28

(S.R.) 50) The Govt's proposals may be accepted

Law Secy 29/11

51) Please put up the rules 7/12/28

52) The rule runs as under

Special licenses for the possession of dangerous

GEN. & REV. SECRETARIAT. 29 NOV. 1928 DEVELOPMENT BRANCH.

NOTE—Contn. Sheet.

WD 01714—GPB—30,000—18-4-28.

General and Revenue Secretariat | Sept File No. 95 of 1927

Serial No.

petroleum in receptacles containing more than 65 gallons, but not more than 2000 gallons each may be granted on such terms as the form may prescribe on the recommendation of the Chief Inspecting Explosives"

53) Form Q - which is the form now in force is all right except in regard to condn 1 printed on the reverse, which in prescribing the details of the tanks, fixes the maxm quantity of petrol that can be stored at 500 gallons*. This form can therefore be used only for licenses to store more than 65 and not more than ~~2000~~ 500 gallons. The Condition 1 is I think patently faulty, for it is not in accord with the rule which fixes a limit of 2000 gallons and not 500 gallons. The position now is that if a license has to be given for a quantity between 500 & 2000 gallons Form Q will not do - though such a license can be given under rule 6.

54) It is conceivable - and the case has actually risen - that a license may be asked for a larger quantity than 2000 gallons. Such a license cannot be granted under rule 6 at all.

55) I think that what is required now is an amendment of rule six * deleting the words "but not

* This figure seems to have been fixed because it represented the standard capacity of the Kerbside pumps, and because it was sought to delegate to the Dir. power to license them.

It is this that is responsible for the anomaly noticed by the 1st Member in para 37, above.

WD 021—GPB—30,000—21-8-28

General and Revenue Secretariat. Genl File No. 95 of 1927.

Serial No.

more than 2000 gallons each"

56) Condition 1 of Form Q will also have to be revised by deleting "500 gallons" and substituting therefor a blank space in which the capacity licensed in each case can be entered One form will then serve for all spl licenses.

57) The fees of course will be as prescribed in Chap VI

58) Revised draft as above is submitted

1st Member 7/12/28

59) A separate notifn under Sec. 23(2) of the Petroleum Regn I of 1923 seems necessary

60) Revised draft S.O. & a notifn are submitted. for consdn. as directed

61) Whether the notifn should issue after previous publication in the Gaz. as per Sec. 23(1) of the Regn is also a point for orders

10/12/28

62) Please bring up

10/12/28

63) Clean off as revised

11/12/28

NOTE—Contn. Sheet.

WD 01714—GPB—30,000—18-4-28

6110-27
(13-25)

13

App. F. III—2]

General and Revenue Secretariat | Geol File No. 95 of 1927.

Serial No.

64) Typed draft ruled
12/12/28 65) For orders
Please see paras. 5 2 6 5 8
of note

12 12 28
MS

1st Nov.

66) Draft appd
67) Amendments of Rules requiring Notification for public Criticisms. under Sec 23 (1) and action accordingly May be taken. Long notice is not necessary. One month will do

14.12.25

14 12 28
15/12

68) Draft notifn ruled. are personally directed

17.12.28 69) Both appendices which is in the file will not be issued. Only the copies of the time, given in this notification It may have also been modified slightly later on.

Secy. Govt

70) Issue
MS 15/12

17/12

18/12/28

NOTE—Contn. sheet

WD 021—GPB—30,000—21-8-28

File
D.D.C. 1928
No. 3628

General and Revenue Secretariat | Geol File No. 95 of 192 7

Serial No.	
7	To the Comptroller No. D. 6485 dt 21.12.28 notifies the publication of a notifn regarding the amendments proposed to be made to the Petroleum Rules and calling for suggestions or objections from the persons likely to be affected thereby before the 29th Jany. 1929 No. D. 6486 dt 21.12.28 to the Dir. of Ste forwards copy of the above —
8	from the Dir. of Ste No. C-147/28-29 dt 29.1.29 states that conditions in Form R proposed to be revised require further modifications in the light of the information recd. from the Chief Inspr of Explosives in Br. India, and requests that the necessary corrections ~~may be~~ pointed out may be incorporated. 7) The period stipulated in the notifn was 29.1.29, and no objection has been recd. from the public. 72) The Dir. has proposed further amendments to the conditions & the form of the license ~~fee~~ ~~acc~~

Gen. Secretariat 28 Dec 28 Govt. Secretariat Branch 4/2/29

Letter dt 31.1.29

NOTE—Contn. sheet

General and Revenue Secretariat | Ref File No 95 | App. F. III—2] of 1927.

Serial No.

+ P

proposed to be issued subsequent to the issue already asked. with the amendments now suggested is filed. herewith for consideration.

74/ Whether a fresh notice calling for the opinion & objections from the persons likely to be affected thereby is to issue on the conditions now proposed by the Dir. to be embodied & a final notice should issue is for orders

sig.
75/ 31.1.29
Subsequent fresh amendments have been suggested by the Director & before they are adopted they have to be notified & opinions obtained again.

Ref 31/1 day of Cer 31.1.29

76/ This may be done

6 2 29
Cer 6/2

77/ Opt ref. 7.2.29

78/ Opn for approval day of Cer 8.2.29

1st Member

1 FEB. 1929 No. 4829

1 c 2 29

79/ Issue 13/2/29

14/2.

NOTE—Contn. sheet

WD 021—GPB—30,000—21-8-28

General and Revenue Secretariat

Govt File No 95 of 192 29

Serial No.	
9	To the Compiler, Mysore Gaz No D. 8675 dy 21.2.29 notifies the publication of certain revised draft amendments which the Govt. purpose to make to the rules under the Petroleum Regns & states that they will be taken into consideration on or after 15.3.29 To the Dir. of Agr No. D. 8676 dy 21.2.29 forwards copy of the above & the stipulated period, viz. 15.3.29 covering upto referred to in the above notifn having lapsed & no objections received it is necessary to issue the final notifn The original draft G.O. already in the file with some pencil alterations & a draft notifn are submitted for appl Sd SDR Secy to 20/3/29 1st Member
25	

For Bill
REV. DEPT. 22/3/29
22 FEB. 1929
DEVELOPMENT BRANCH

5961

Cm 26/3/29

29 3 29

Cm 30.3.29

Issue

30 3 29

NOTE.—Contn. sheet

Serial No.	
10	To the Dir. of Ptc " District Magistrates & " Supdt. Govt. Printing No. D 10424-33 dt 11-6-29. Prescribes certain amendments to the Petroleum Rules & revises form Q of the Petroleum rules issued with G.O. dt 28-9-28.
11	To the Compiler Rules. No. D. 10434 dt 11-4-29 Notifies the publication of a notification amending rule 6 - cl. IV of the Rules and form Q & Conditions thereto To the Director Ptc. No. D 10435-9 11/6/29 Forwards copies of the above



NOTE—Contn. sheet

App. F. VI G 10.

(18)

Government of His Highness the Maharaja of Mysore.

GENERAL AND REVENUE DEPARTMENTS

Special licenses for the possession & dangerous petroleum orders ~~possession~~ certain amendments to rules under the Mysore Petroleum Regulations and premises forms B & for the issue of

G. O. No. D. 10424-33 Genl. 95-27-10 DATED 11th April 1929

May this be

i. printed? Yes

ii. treated as a standing order? Yes

iii. published in the Gazette English Part? Yes

iv. translated? Yes

v. placed at the disposal of the press? Yes

vi. published in the Gazette Kannada Part? Yes

S.O. 12/4 12.4.29

Encl. 95-27-1

TELEGRAPHIC ADDRESS :— "INDUSCOM."

In reply please refer to No. Cz - 1488 - 27

GOVERNMENT OF MYSORE.

DEPARTMENT OF INDUSTRIES AND COMMERCE.

Encl- Three

OFFICE OF THE DIRECTOR,

Dated Bangalore, the 21st January *1928*

2370

D. 6110

FROM

C. RANGANATHA RAO SAHIB, ESQ., B.A., B.L.,
Director of Industries and Commerce in Mysore,
(Bangalore India.)

Encl

To

N. RAMA RAO, ESQ., B.A., B.L.,
SECRETARY TO THE GOVERNMENT OF MYSORE,
DEVELOPMENT DEPARTMENTS, BANGALORE.

Please examine with reference to legal provisions & put up.

SIR,

I have the honor to state that Messrs. The Tank Storage Co (India) Ltd., Bombay, have applied for a special license to store 10,000 gallons of dangerous petroleum in bulk in one tank completely buried underground inside their bulk petrol Depot recently constructed at Birur. The prescribed fee of Rs.40/- has been collected from the Company and credited to the State Huzur Treasury on 15th November 1927.

1) The License applied for by the Company is a special license under Cl.6.Chap.IV.Part II of the rules. According to the provisions of Cl.6, as it stands at present, special licenses can only be issued in respect of receptacles whose capacity is not less than 65 gallons and not more than 2,000 gallons each. Licenses in form Q are now being issued under this clause in respect of tanks near Kerbside pumps. The Tank which the Company have now erected has a capacity of 10,000 gallons and they want a special license in respect of this tank under Cl. 6, IV, Part II of the Rules.

Chap.

3) This storage tank does not satisfy the conditions of the License form P which also permits the storage of dangerous petroleum in a bulk condition. In this connection I addressed the Chief Inspector of Explosives in British India requesting him to let me know if any limit is fixed in British India in the special licenses issued under Rule 6. Chp.IV.Part II of the rules with regard to the quantity of dangerous petroleum that is permitted to be stored in bulk in

underground tanks. Copy of his letter No.P.2.(61) dated 6th January 1928 received in reply, together with a copy of the form of the special license issued in British India is enclosed herein for kind reference. It is seen therefrom that there is no limit fixed with regard to the quantity that may be stored in bulk in such tanks. I may also state for the information of Government that the underground tank in respect of which these special licenses are issued are constructed generally by the principal Oil Companies under the supervision of the properly qualified technical men and according to the standard design approved by the Chief Inspector of Explosives in British India.

4/ The conditions subject to which such special licenses are to be issued have not yet been prescribed by Government. I therefore request that the approval of Government may be kindly obtained for the form of the special license enclosed herein and also the conditions appended to it.

5/ I may also be empowered to issue such special licenses in future.

I have the honor to be,

Sir,

Your most obedient servant,

Director-in-charge.

MSR.

Copy of letter No.P-2(61) dated 6th January 1928 from the Chief Inspector of Explosives in India, Calcutta to the Director of Industries and Commerce in Mysore, B a n g a l o r e.

With reference to your letter No. C.2-1488/27 dated the 20th/21st December 1927, I have the honor to state that no limit has been fixed to the quantity of dangerous petroleum that can be stored in bulk in underground tanks to be covered by a special license under Rule, 6, Chapter IV, Part II of the Petroleum Rules. A copy of the special license ~~from~~ form with conditions which have to be ordinarily observed is enclosed.

****

Ramanlia Abraham
D i r e c t o r - i n - c h a r g e

MSR.

4

A. P. F. VI. G[illegible]

SUBJECT.....

.....

.....

Section Excl

File No. 95-27

Serial No. 5

No. D 2801

Diary No. of letter replied to.....

General and Revenue Secretariat

( )

the *192*

To The Dist. Magte

.....

Date of issue 5/9/28

Signed by. Mr V. V. Sharey.

Sir,

With reference to your letter no. C2-1488/27 & 21st/23rd Jany. 1928 suggesting a special license form for keeping dangerous petroleum in receptacles containing more than 2000 gallons contemplated in rule 6. cl. IV. Part II of the Rules under the Explosive Petroleum Rules I am directed

List of enclosures.....

Copied by .....

Examined by .....

over

5

to request you to furnish information on ~~one of~~ the following points

1) Whether it is necessary to have two forms (Q & the new form suggested) of licenses issued under one Rule (No. 6 - Cl. IV)

2) Whether there are two such forms in use in Br. Indian

3) Whether only one form is sufficient in case the words "not more than two gallons each" in Rule 6 are deleted

4) What the British Indian penalties in such cases is.

The favour of an early reply is requested

I have the

2nd

NP
5/9 Dep: Secy

DEPARTMENT OF INDUSTRIES AND COMMERCE.

2190

D.O. No. C2-1488/27-28

OFFICE OF THE DIRECTOR,

Bangalore, dated the 10th Sept. *1928*

SFK 1928

Dear Mr. Vedavyasacharya,

May I request you to kindly return for reference the copy of the form of special license and conditions appended thereto, which had been sent for reference of Government enclosed with this office letter No.C2-1488/27-28 dated 23rd January 1928 so as to enable this office to furnish the information on the several points raised by Government in their letter No. D-2801/Geol.95-9-5 dated 5th September 1928 in regard to the grant of special licenses under clause 6, Chapter IV part II of the Petroleum Rules for possession of dangerous petroleum in receptacles containing more than 2000 gallons?

Yours Sincerely,

To

V. Vedavyasacharya, Esq., B.A. (Hons.,)
Assistant Secretary,
Development Departments, BANGALORE.

ksv.

(7

A. P. F. VI. G1]

SUBJECT.....

.....

.....

Section Land

File No. 95-27

Serial No.

No. D 3472 (and one)

Diary No. of letter replied to 2170

General and Revenue Secretariat

( )

the *192*

To .....

Date of issue 20-9-28

Signed by M. V. Acharya

Dear Sir,

As desired in Secret D.O. letter Rec. C_2-1488/27-28 dt 11.9.28 I send herewith the copy of the form of Special Licence proposed to be introduced in connection with the grant of Special Licences under cl 6 Chap. IV - Part II of the Petroleum Rules and request that the same may be returned with

List of enclosures.....

Copied by .....

Examined by .....

over

WD0125—GPB—30,000—26-5-27

8

The reply called for in this
office letter No. D. 2801 - Ecal.
46 - 27 - 5 dy 5.9.28 at are can by date

Yours sincerely

WH

14/9

20

W. H. Rammurat Esqr Bk

Geol. 95-27-6

(9)

TELEGRAPHIC ADDRESS :— "INDUSCOM"

In reply please refer to
No. C.2. 1488/27-28
Encls:— Nil.

GOVERNMENT OF MYSORE.

DEPARTMENT OF INDUSTRIES AND COMMERCE.

REV. SECRETARIAT 4039 21 NOV 1928 DEVELOPMENT BRANCH

OFFICE OF THE DIRECTOR,

Dated, Bangalore, 20th Novr. 1928.

FROM

C. RANGANATHA RAO SAHIB, ESQ., B.A., B.L.,
Director of Industries and Commerce in Mysore,
Bangalore (India.)

To

N. RAMA RAO, ESQ., B.A., B.L.,
Secretary to Government, Development Depts.
B A N G A L O R E.

SIR,

With reference to your letter No. D-2801/Geological. 95-27-5 dated the 5th September 1928, calling for certain information with regard to the grant of special licenses, I have the honour to state as follows:-

1) In view of the present wording of Rule 6 Chapter IV part 2 of the Rules, it is necessary to have two forms of special Licenses Form "Q" is intended to cover storage of petrol in receptacles or tanks whose capacity is above 65 gallons and below 500 gallons Another form has to be introduced to cover storage when the quantity so stored, exceeds 500 gallons but not 2000 gallons.

2) In British India, the wording of corresponding Rule provides for the issue of a Special License covering any quantity above 65 gallons. A copy of letter No. P-2(61) dated 6th January 1928 is enclosed.

3) Only one form of special License will do for the State, if the words "but not more than 2000 gallons each" are deleted from the present Rule 6.

4) In British India only one form of special License is in use.

To bring our Rules into a line with the Rules in British India, I suggest the desirability of deleting the words referred to in clause 3 above.

I.T.O.

There will, then, be no need to have two different forms of special licenses. I request the favour of very early orders on the subject as the Oil Company are pressing for the grant of a license, at an early date.

Copy of the form of special license received with your D.O. letter No. 3472 dated the 20th September 1928 is returned herewith for reference.

I have the honour to be,

Sir,

Your most obedient servant,

(Ranganatha Rao Sahib)

K.V.

D I R E C T O R.

Letter No. P-2(61) dated the 6th January 1928, from the Chief Inspector of Explosives in India to the Director of Industries and Commerce, in Mysore.

With reference to your letter No. C2-1488/27 dated the 20th/21st December 1927, I have the honour to state, that no limit has been fixed to the quantity of dangerous petroleum that can be stored in bulk in underground tanks, to be covered by a special license under Rule 6, Chapter IV, Part II of the Petroleum Rules. A copy of the special license form with conditions which have to be ordinarily observed, is enclosed.

"Copy"

Director

ksv.

Appendix F G—1

13

SUBJECT.....

.....

.....

Section Geol

File No. 95-27

Serial No. 7

No. D. 6485

Diary No. of letter replied to.....

General and Revenue Secretariat

( )

the 192

To

.....Notification.....

Date of issue 21/12/28

Signed by Mr. N. Rama Rao

The following draft amendments which the Govt. purpose to make in exercise of the powers conferred on them under Sec 8 of the Petroleum Regns I of 1924 to the Rules framed thereunder and issued with Notifn No D. C. 5416/Geol. 103-22-14 of 13-3 1924 are hereby published for the information of the persons likely to be affected thereby and notice is hereby

List of enclosures.....

Copied by.....

Examined by.....

over

ex thate the amendments
will be taken into consideration
on or after the 29th day of 1929,
and that suggestions or objections
which may be received from
any person with refer to the
said amendments before the
date aforesaid will be con-
sidered by Govt

Amendments

1) Rule 6, chap. IV - Part II.

Omit the words "but
not more than 2 ons of allows
each"

2) Form Q of the License form

Revise the existing form + Conditions to the form and conditions as amended.

By order

Sec: to Govt.

Dev: Depts.

To the Compiler. Signore Sec. for publication

memo.

No. D 6486/9 21/12

Copy forwarded to the Dir. of Ste for information

By order

Sec. Dev. Depts

(1) Form R

or more than one receptacle forming one unit and

Special License to possess dangerous petroleum in one receptable containing more than sixty-five gallons. 15

(Rule 6, Chapter IV of Part II.)

No. Fee Rs.

License is hereby granted to

for the storage

in the licensed premises described below of gallons of dangerous petroleum in one tank subject to the rules for the storage of petroleum published in notification No , dated

and to the further conditions attached hereto.

The 19 Secretary to the Government of

[Description of the licensed premises above referred to.]

The licensed premises are situated

and

consist of a gas-tight tank of a capacity of gallons sunk underground.

11 Portable pump

(2)

Conditions of license.

2. The petroleum shall be stored in one gas-tight metal tank of a capacity of gallons sunk completely underground in the position shown on plan submitted, and placed in a pit lined with concrete or brick in cement, the tank being packed round with sand, earth or clay, so that no air space is left below ground level and the tank is not visible.

3. A pump or pumps shall be placed in the position shown on plan submitted, the pipe connection between the tank and the pump or pumps shall be placed underground and all joints, valves and cocks shall be gas-tight.

4. For the purpose of charging the tanks of locomotives the petroleum shall be—

(*a*) pumped through strong metal piping by means of approved pumps into above-ground measuring tanks of a capacity not exceeding 30 gallons, fixed in approved positions, and run thence through sound hose, fitted with secure self-closing cock and nozzle, into the tanks of locomotives, or

(*b*) pumped through strong metal piping by means of approved pumps into an above-ground service tank of approved capacity, fixed in an approved position, and run thence through strong metal piping into measuring tanks of a capacity not exceeding 30 gallons fixed in approved positions, and thence through sound hose, fitted with secure self-closing cock and nozzle, into the tanks of locomotives, or

(*c*) pumped by means of approved measuring pumps, fixed in approved positions, through sound hose fitted with secure tap and nozzle, into the tanks of locomotives.

All tanks, pumps, pipes and fittings shall be strongly constructed of the best materials.

All service or measuring tanks shall be fitted with overflow and emptying pipes returning to the storage tank.

The petroleum shall enter the tank "under seal" and all tanks shall be fitted with a vent pipe leading into the open air, the open end being covered with brass gauze, 32 mesh, and fitted with a hood or the open end shall be fitted with an inlet valve and an exhaust valve.

If the licensing officer call upon the holder of a license by a notice in writing, to execute any repairs to the storage premises, which may, in the opinion of such officer, be necessary for the safety of the said premises, the holder of the license shall execute the repairs within such period, not being less than one month from the date of receipt of the notice as may be fixed by the notice.

The tank, before being repaired, shall be cleared of all dangerous petroleum and of all dangerous vapours arising from the same.

9. The license holder is prohibited from delivering any quantity of dangerous petroleum exceeding three gallons to any one who has not a license under section 5 or section 6 of the Act.

10. All due precautions shall be taken for the prevention of unauthorised persons having access to any petroleum kept and to the vessels containing or having actually contained the same.

11. Every person managing or employed on or in connection with the storage premises shall abstain from any act whatever which tends to cause fire or explosion and which is not reasonably necessary, and shall prevent any other person from doing such act.

12. The storage premises shall be liable to inspection by an officer not being of lower rank than a Sub-Inspector of Police authorised by the Local Government in this behalf.

14. This license shall be held to cover the use of a portable kerbside pump outfit for a period of not more than one month in the place of the licensed permanent outfit in the event of the latter being out of order provided notice in writing is given to the District Authority before the portable pump is taken into use.

Geol 95-27-8 (17)

TELEGRAPHIC ADDRESS :— "INDUSCOM"

In reply please refer to
No. C2-147/28-29.
Encls:— one Two

GOVERNMENT OF MYSORE.

DEPARTMENT OF INDUSTRIES AND COMMERCE.

OFFICE OF THE DIRECTOR,

Dated, Bangalore, 28th Jan. *192* 9.

29 JAN. 1929

FROM

C. RANGANATHA RAO SAHIB, ESQ., B.A., B.L.,
Director of Industries and Commerce in Mysore,
Bangalore (India.)

CEN. & REV. SECRETARIATE 27 30 JAN. 1929 DEVELOPMENT BRANCH

To

N. RAMA RAO, ESQ., B.A., B.L.,
Secretary to Government, Development Department,
BANGALORE.

SIR,

With reference to the Notification No. D6485-Geol.95-27-7 dated the 21st December 1928 appearing on page 7, Part II of the Mysore Gazette dated the 3rd January 1929 publishing for the information of the general public, the amendments to be made to Rule 6 Chapter IV Part II of the Petroleum Rules and also to the conditions of the license in form "Q", I have the honor to state that I have been in correspondence with the Chief Inspector of Explosives in British India and have obtained from him a copy of the Special license as recently revised, and I enclose herein for your reference a copy of the same. The conditions of the license as published in the Gazette have to be slightly altered as shown in the memo appended hereto. I request that necessary action may kindly be taken to revise the conditions of the license as pointed out in the memo.

I have the honour to be

Sir,

Your most obedient servant

C Ranganatha Rao Sahib

DIRECTOR

M E M O.

Conditions of Special License.

Clause 1. "Condition 9" may be altered as "Condition 8."

1.(First line) after condition 9 insert the following words "or for testing the accuracy of a pump's discharge by means of a standard capacity measure."

Clause 4(a) (Last line) after the word Nozzle insert the following words - "into the Tanks of locomotives or".

Omit clause 6.

The figures of clauses "7,8,9,10,11,12,13, and 14 may be renumbered altered as 6,7,8,9,10,11,12,and 13."

Clause 9. After the words "vapours arising from the same", insert the following words "When a tank in position is open for cleaning or repairs, no lamps of any discription either ordinary, electric, electric torches or electric cables or electric fans shall be brought near the man-hole of the tank (the inside of the tank may be lighted by the use of mirrors)."

Clause10. For the word "Act" substitute "Regulation".

Clause13. Omit the word "Local" behind "Government"

Clause14. (last line) alter "District Authority" to "Director of Industries and Commerce" Form Q.

or

Insert "Officer appointed by Government in this behalf" after Secretary to Government."

Omit "in the petrol godown" after the words "sunk underground"

Director.

(19

or more than one receptacle forming one unit and

Special License to possess dangerous petroleum in one receptacle containing more than sixty-five gallons.

(Rule 6, Chapter IV of Part II.)

No. Fee Rs.

License is hereby granted to

for the storage

in the licensed premises described below of gallons of dangerous petroleum in one tank subject to the rules for the storage of petroleum published in notification No. , dated and to the further conditions attached hereto.

The 19 Secretary to the Government of or the officer appointed by Govt in this behalf

[Description of the licensed premises above referred to.]

The licensed premises are situated and consist of a gas-tight tank of a capacity of gallons sunk underground.

90

or for testing the accuracy of a pump's discharge by means of a standard capacity measure

Conditions of license.

1. Except when absolutely necessary for the purposes of condition 3 or when the tank and pump are erected completely inside a Dangerous Petroleum Installation, petroleum shall, on no account be filled from the tank or pump or from a barrel of oil supplied by Petroleum Companies to be filled into the tank, into any receptacle other than that clamped or fitted to a Motor Vehicle.

2. The petroleum shall be stored in one gas-tight metal tank of a capacity of gallons sunk completely underground in the position shown on plan submitted, and placed in a pit lined with concrete or brick in cement, the tank being packed round with sand, earth or clay, so that no air space is left below ground level and the tank is not visible.

3. A pump or pumps shall be placed in the position shown on plan submitted, the pipe connection between the tank and the pump or pumps shall be placed underground and all joints, valves and cocks shall be gas-tight.

4. For the purpose of charging the tanks of locomotives the petroleum shall be—

(*a*) pumped through strong metal piping by means of approved pumps into above-ground measuring tanks of a capacity not exceeding 30 gallons, fixed in approved positions, and run thence through sound hose, fitted with secure self-closing cock and nozzle, into the tanks of locomotives, or

(*b*) pumped through strong metal piping by means of approved pumps into an above-ground service tank of approved capacity, fixed in an approved position, and run thence through strong metal piping into measuring tanks of a capacity not exceeding 30 gallons fixed in approved positions and thence through sound hose, fitted with secure self-closing cock and nozzle, into the tanks of locomotives, or

(*c*) pumped by means of approved measuring pumps, fixed in approved positions, through sound hose fitted with secure tap and nozzle, into the tanks of locomotives.

5. All tanks, pumps, pipes and fittings shall be strongly constructed of the best materials.

~~6. All service or measuring tanks shall be fitted with overflow and emptying pipes returning to the storage tank.~~

6. ~~5~~ The petroleum shall enter the tank "under seal" and all tanks shall be fitted with a vent pipe leading into the open air, the open end being covered with brass gauze, 32 mesh, and fitted with a hood or the open end shall be fitted with an inlet valve and an exhaust valve.

7. ~~8~~ If the licensing officer call upon the holder of a license by a notice in writing, to execute any repairs to the storage premises, which may, in the opinion of such officer, be necessary for the safety of the said premises, the holder of the license shall execute the repairs within such period, not being less than one month from the date of receipt of the notice as may be fixed by the notice.

8. ~~9~~ The tank, before being repaired, shall be cleared of all dangerous petroleum and of all dangerous vapours arising from the same. When a tank in position is open for cleaning or repairs no lamps of any description either ordinary, electric, electric torches or electric cables or electric fans shall be brought near the manhole of the tank (the inside of the tank may be lighted by the use of mirrors).

9. ~~10~~. The license holder is prohibited from delivering any quantity of dangerous petroleum exceeding three gallons to any one who has not a license under section 5 or section 6 of the ~~Act~~ Regulation.

10. ~~11~~. All due precautions shall be taken for the prevention of unauthorised persons having access to any petroleum kept and to the vessels containing or having actually contained the same.

11. ~~12~~. Every person managing or employed on or in connection with the storage premises shall abstain from any act whatever which tends to cause fire or explosion and which is not reasonably necessary, and shall prevent any other person from doing such act. No fire or naked light shall be allowed to burn and no smoking or the lighting of any match shall be permitted within ten feet of a kerbside pump.

12. ~~13~~. The storage premises shall be liable to inspection by an officer not being of lower rank than a Sub-Inspector of Police authorised by the ~~Local~~ Government in this behalf.

13. ~~14~~. This license shall be held to cover the use of a portable Kerbside pump outfit for a period of not more than one month in the place of the licensed permanent outfit in the event of the latter being out of order, provided notice in writing is given to the ~~District Authority~~ Director of Industries Haryana before the portable pump is taken into use.

GIPD—668-Std. S. (Agency)—23-11-27—3,000.

Appendix F G—1

22

SUBJECT.....

.....

.....

Diary No. of letter replied to 6270

General and Revenue Secretariat

( )

the 192

Date of issue 21.2.29

Signed by Mr. C.E.N.

List of enclosures.....

Copied by.....

Examined by.....

Section Genl

File No. 95-27

Serial No. 9

No. D 8375

To

Notifn.

In modification of the notifn published at pages 2 & 3 of Part II - Sec. 2 of the Bombay Govt Gazette dt 3rd January 1929 under No. D. 6485/Genl. 95-27-7 of 21.12.28 the following proposed draft amendments which the Govt. propose to make in exercise of the powers conferred on them under Sec. 8 of the Burma Petroleum Regn. I of 1923 to the Rules framed thereunder are

over

hereby published for the information of the persons likely to be affected thereby, and notice is hereby given that the proposed amendments will be taken into consideration on or after the 15th* day of May, and that suggestions or objections, if any, which may be received from any person with reference to the said amendments before the date aforesaid will be considered by Govt

Amendments

1) Rule 6, Chap. IV - Part II

Omit the words "but not more than 2000 gallons each".

2) Form Q of the licence form

"Revise the existing form & Conditions to the form and conditions as hereto annexed.

By order

Secy. to Govt.

Dev: Depts

* 20

The Compiler, Mysore

(24)

G. R. S. App F. G. 3.

GENERAL AND REVENUE SECRETARIAT.

(Continuation sheet draft form.)

Gazette for publication
in the Gazette

memo. No: D 8276.

Copy forwarded
with compliments to the
Dir. of Ind. with reference to
his letter no. C2-147/28-29
dt 28-1-29.

By order

for Secy. to Govt.
Genl: Depts

30

Clk
8.2.29

WD 0327—GPB—10,000—18-5-27

25

~~No. I. C. 2118-27—Geol. 29-26-2, dated 8th September 1926.~~

FORM Q.

Special License to possess dangerous petroleum in one receptable or more than one receptacle forming one unit or containing more than sixty-five gallons.

(*Rule 6, Chapter IV of Part II.*)

No. Fee Rs. eight.

License is hereby granted to Messrs.....
.....for the storage in the licensed premises described below of.....gallons of dangerous petroleum in one tank subject to the rules for the storage of petroleum published in Notification No. I. C. 5415—Geol. 103-22-14, dated the 13th March 1924 as subsequently amended and to the further conditions attached hereto.

The.....192 Secretary to Government.
or
The Officer appointed by Govt. in this behalf

(Description of the licensed premises above referred to.)

The licensed premises are situated at No.....
.....and consist of a gas tight tank of a capacity of.....gallons sunk underground ~~in the petrol godown~~.

~~W. D. 771—G P B—640—13-10-26~~

Conditions as originally proposed and approved by Govt

Except when absolutely necessary for the purposes of condi- 2)
9. ~~or~~ when the tank and pump are erected completely inside a
~~Dangerous~~ Petroleum Installation petroleum shall on no account be
~~filled~~ from the tank or pump or from a barrel of oil supplied by ~~Exxn~~
Petroleum Companies to be filled into the tank into any receptacle
other than that clamped or fitted to a Motot Vehicle.

1. The petroleum shall be stored in one gas tight metal tank of a capacity of.....
gallons sunk completely underground in the position shown on plan submitted, and placed
in a pit lined with concrete or brick in cement, the tank being packed round with sand,
earth or clay so that no air space is left below ground level and the tank is not visible.

3. A pump or pumps shall be placed in the position shown on plan submitted, the
pipe connection between the tank and the pump or pumps shall be placed underground
and all joints, valves and cocks shall be gas tight.

4. For the purpose of charging the tanks of locomotives the petroleum shall be: 4(a)
(a) Pumped through strong metal piping by means of approved pumps into above-
ground measuring tanks of a capacity not exceeding 30 gallons, fixed in approved posi-
tions, and run thence through sound hose, fitted with secure self closing cock and nozzle,
(b) Pumped through strong metal piping by means of approved pumps into an
above-ground service tank of approved capacity, fixed in an approved position, and run
thence through strong metal piping into measuring tanks of a capacity not exceeding 30
gallons, fixed in approved positions and thence through sound hose, fitted with secure self
closing cock and nozzle, into the tanks of locomotives, or
(c) Pumped by means of approved measuring pumps, fixed in approved positions,
through sound hose fitted with secure tap and nozzle, into the tanks of locomotives.

5. All tanks, pumps, pipes and fittings shall be strongly constructed of the best 6.
materials.

6. All service or measuring tanks shall be fitted with overflow and emptying pipes
returning to the storage tank.

7. The petroleum shall enter the tank "under seal" and all tanks shall be fitted 7-14
with a vent pipe leading into the open air, the open end being covered with brass gauze 32
mesh and fitted with a hood or the open end shall be fitted with an inlet valve and an
exhaust valve.

8. If the licensing officer call upon the holder of a license by a notice in writing, to
execute any repairs to the storage premises, which may, in the opinion of such officer be
necessary for the safety of the said premises, the holder of the license shall execute the
repairs within such period, not being less than one month from the date of receipt of the
notice as may be fixed by the notice. 9. A

9. The tank before being repaired, shall be cleared of all dangerous petroleum and
of all dangerous vapours arising from the same.

10. The license-holder is prohibited from delivering any quantity of dangerous
petroleum exceeding three gallons to any one who has not a license under Section 5 or
Section 6 of the ~~Act.~~

11. All due precautions shall be taken for the prevention of unauthorised persons
having access to any petroleum kept and to the vessels containing or having actually con-
tained the same

12. Every person managing or employed on or in connection with the storage or
premises shall abstain from any act whatever which tends to cause fire or explosion and
which is not reasonably necessary and shall prevent any other person from doing such act.

~~No~~ fire or naked light shall be allowed to burn and no 10.
smoking or the lighting of any match shall be permitted within ten
feet of a kerbside pump.

13. The storage premises shall be liable to inspection by an officer not being of lower 13
rank than a Sub-Inspector of Police authorised by the Local Government in this behalf.

~~14. On no account shall tins or drums be filled with dangerous petroleum from the~~ 14
~~pump or pumps.~~

14. This license shall be held to cover the use of a portable
kerbside pump outfit for a period of not more than one month in the
place of the licensed permanent outfit in the event of the latter
being out of order provided notice in writing is given to the
District Authority before the portable pump is taken into use.

Conditions as originally proposed and approved by Govt.

1) 2) A

~~1.~~ Except when absolutely necessary for the purposes of condition 9, and when the tank and pump are erected completely inside a Dangerous Petroleum Installation petroleum shall on no account be filled from the tank or pump or from a barrel of oil supplied by the Petroleum Companies to be filled into the tank into any receptacle other than that clamped or fitted to a Motot Vehicle.

~~2.~~ The petroleum shall be stored in one gas tight metal tank of a capacity of..... gallons sunk completely underground in the position shown on plan submitted, and placed in a pit lined with concrete or brick in cement, the tank being packed round with sand, earth or clay so that no air space is left below ground level and the tank is not visible.

~~3.~~ A pump or pumps shall be placed in the position shown on plan submitted, the pipe connection between the tank and the pump or pumps shall be placed underground and all joints, valves and cocks shall be gas tight.

~~4.~~ For the purpose of charging the tanks of locomotives the petroleum shall be:

~~5~~ 4 (a) Pumped through strong metal piping by means of approved pumps into above-ground measuring tanks of a capacity not exceeding 30 gallons, fixed in approved positions, and run thence through sound hose, fitted with secure self closing cock and nozzle,

(b) Pumped through strong metal piping by means of approved pumps into an above-ground service tank of approved capacity, fixed in an approved position, and run thence through strong metal piping into measuring tanks of a capacity not exceeding 30 gallons, fixed in approved positions and thence through sound hose, fitted with secure self closing cock and nozzle, into the tanks of locomotives, or

(c) Pumped by means of approved measuring pumps, fixed in approved positions, through sound hose fitted with secure tap and nozzle, into the tanks of locomotives.

~~6.~~ All tanks, pumps, pipes and fittings shall be strongly constructed of the best materials.

~~7.~~ All service or measuring tanks shall be fitted with overflow and emptying pipes returning to the storage tank.

~~8.~~ The petroleum shall enter the tank "under seal" and all tanks shall be fitted with a vent pipe leading into the open air, the open end being covered with brass gauze 32 mesh and fitted with a hood or the open end shall be fitted with an inlet valve and an exhaust valve.

~~9.~~ If the licensing officer call upon the holder of a license by a notice in writing, to execute any repairs to the storage premises, which may, in the opinion of such officer be necessary for the safety of the said premises, the holder of the license shall execute the repairs within such period, not being less than one month from the date of receipt of the notice as may be fixed by the notice.

~~10.~~ The tank before being repaired, shall be cleared of all dangerous petroleum and of all dangerous vapours arising from the same.

~~11.~~ The license-holder is prohibited from delivering any quantity of dangerous petroleum exceeding three gallons to any one who has not a license under Section 5 or Section 6 of the ~~Act~~.

~~12.~~ All due precautions shall be taken for the prevention of unauthorised persons having access to any petroleum kept and to the vessels containing or having actually contained the same

~~13.~~ Every person managing or employed on or in connection with the storage or premises shall abstain from any act whatever which tends to cause fire or explosion and which is not reasonably necessary and shall prevent any other person from doing such act.

~~14.~~ ~~No~~ fire or naked light shall be allowed to burn and no smoking or the lighting of any match shall be permitted within ten feet of a kerbside pump.

~~15.~~ The storage premises shall be liable to inspection by an officer not being of lower rank than a Sub-Inspector of Police authorised by the Local Government in this behalf.

~~16.~~ On no account shall tins or drums be filled with dangerous petroleum from the pump or pumps.

14. This license shall be held to cover the use of a portable kerbside pump outfit for a period of not more than one month in the place of the licensed permanent outfit in the event of the latter being out of order provided notice in writing is given to the District Authority before the portable pump is taken into use.

Alterations now suggested.

'der "g" in line 2 and '8'
after g and" or for testing the accuracy
.a pump's discharge by means
.a standard capacity measure".

-d at the end " into the Tanks of
ocomotives or":

mit clause 6.

Renumber them as "6-13"

d at the end " on a tank in position
en for cleaning or repairs, no lamps
ny description either ordinary,
tric, electric torches or electric
les or electric fans shall be brought
by the manhole of the tank (the inside
tank may be lighted by the use of
ators)".

Substitute "Regulation" for "Act" at
e end.

mit "Local" in line 2.

Substitute "Director of Industries
and Commerce" for "District
Authority" occurring in the last line.

S. O.

Government of his highness the Maharaja of Mysore.

GENERAL AND REVENUE DEPARTMENTS.

G. O. No. D. 10424-33—Geol. 95-27-10, dated 11th April 1929.

Special Licenses for the Possession of Dangerous Petroleum.

Orders certain amendments to rules under the Mysore Petroleum Regulation and revises form Q for the issue of

---

READ—

Government Order No. I. C. 2118-27—Geol. 29-26-2, dated the 28th September 1926, prescribing a form for the issue of special licenses for the possession of dangerous petroleum in receptacles containing more than 65 gallons, but not more than 2,000 gallons referred to in Rule 6 Chapter IV of Part II of the Petroleum Rules.

2. Correspondence ending with letter No. C^2 147—28-29, dated 28th January 1929, from the Director of Industries and Commerce, stating that the special form "Q" introduced in Government Order dated 28th September 1926, does not answer the purpose in cases where the capacity of the tank is in excess of 2,000 gallons, and since cases had arisen in which licenses in excess of that quantity had been asked for, and suggesting certain amendments to the existing Rule 6 of Chapter IV to avoid inconvenience and to bring the rule in conformity with the one in force in British India.

ORDER NO. D. 10424-33—GEOL. 95-27-10, DATED 11TH APRIL 1929.

The limit of 2,000 gallons fixed in Rule 6 Chapter IV of the rules under Regulation I of 1923, leads to certain anomalies in practice, to avoid which, the Director of Industries and Commerce has recommended the adoption of a new form. But this expedient will not meet the case, and Government are of opinion that it is necessary to amend both Rule 6 and form "Q" in such wise as to render it possible to grant a special license under the amended rule in the same form for storing any reasonable quantity of dangerous petroleum in excess of 65 gallons. They are accordingly pleased to direct as follows:—

Rule 6 Chapter IV shall be amended by the omission of the words "but not more than 2,000 gallons each."

Notification amending Rule 6 Chapter IV, and revising form "Q" will be published separately.

N. RAMA RAO,
Secretary to Government,
Development Departments.

To—The Director of Industries and Commerce in Mysore.
The District Magistrates of Districts.
The Superintendent, Government Printing, for supplying the necessary forms to the Director of Industries and Commerce in Mysore.

Exd.—P. S. R. N.

W D 2919—GPB—635—16-4-29

Draft Ecol. 95-27-10

Proceedings of the Government of H.H. the Maharaja of Mysore.

- o -

R e a d -

Government Order No.I.C.2116-27/Geol.29-26-2, dated 20th September 1926, prescribing a form for the issue of special licenses for the possession of dangerous petroleum in receptacle containing more than 65 gallons, but not more than 2000 gallons referred to in rule 6, Chap. IV of Part II of the Petroleum Rules.

2. Government Order No.I.C.2128/Geol. 29-26-3 dated 28th September 1926, empowering the Director of Industries and Commerce to issue special licenses in form 'Q' of the Petroleum Rules for the possession of dangerous petroleum in receptacles containing more than 65 gallons, but not exceeding 5000 gallons.

2. Correspondence ending with letter No.C.2-1488/28-29 dated 20th November 1928 stating that the special form introduced in Government Order dated 28th September 1926, does not answer the purpose in cases where the capacity of the tank is in excess of 2000 gallons, and since cases had arisen in which licenses in excess of that quantity had been asked for, and suggesting certain amendments to the existing Rule 6 of Chapter IV to avoid inconvenience and to bring the rule in conformity with the one in force in British India.

O r d e r 10424-33

The limit of capacity 5000 gallons prescribed in condition(1) of the form 'Q' now in use and the limit of 2000 gallons fixed in Rule 6 chap. IV of the rules

Two offls

(30)

PROCEEDINGS OF THE GOVERNMENT OF HIS HIGHNESS THE MAHARAJA OF MYSORE.

Read:—

Government Order No.I.C.&113-27/Genl. 29-26-2, dated the 28th September 1926, prescribing a form for the issue of special licenses for the possession of dangerous petroleum in receptacles containing more than 65 gallons, but not more than 2000 gallons referred to in rule 6—Chapter IV of Part II of the Petroleum Rules.

2. Correspondence ending with letter Ng.Cg 147/28-29 dated 28th January 1929 from the Director of Industries and Commerce stating that the special form "Q" introduced in Government Order dated 28th September 1926, does not answer the purpose in cases where the capacity of the tank is in excess of 2,000 gallons, and since cases had arisen in which licenses in excess of that quantity had been asked for, and suggesting certain amendments to the existing Rule 6 of Chapter IV to avoid inconvenience and to bring the rule in conformity with the one in force in British India.

Order No.D. 10424-33/Genl 96-27-10

Dated, Bangalore, 11th April 1929.

The limit of 2000 gallons fixed in Rule 6 of Chapter IV of the Rules under Regulation I of 1923 leads to certain anomalies in practice, to avoid which, the Director of Industries and Commerce has recommended the adoption of a new form. But this expendient will not meet the case and Government are of opinion that it is necessary to amend both Rule 6 and Form "Q" in such wise as to render it possible to grant a special license under the amended rule in the same form for storing any reasonable quantity of dangerous petroleum in excess of 65 gallons. They are accordingly pleased to direct as follows: -

Rule 6 Chapter IV shall be amended by the omission of the words "but not more than 2000 gallons each".

Notification amending Rule 6 Chapter IV and revising form Q

p.t.o.

will be published separately.

By Order,

Secretary to Government.

Development Departments.

To

The Director of Industries and Commerce in Mysore.

The District Magistrates of Districts.

The Superintendent, Government Printing, for supplying the necessary forms to the Director of Industries and Commerce in Mysore.

ACH.6.

32

S. O.

Government of his highness the Maharaja of Mysore.

GENERAL AND REVENUE DEPARTMENTS.

G. O. No. D. 10424-33—Geol. 95-27-10, dated 11th April 1929.

Special Licenses for the Possession of Dangerous Petroleum.

Orders certain amendments to rules under the Mysore Petroleum Regulation and revises form Q for the issue of ——

READ—

Government Order No. I. C. 2118-27—Geol. 29-26-2, dated the 28th September 1926, prescribing a form for the issue of special licenses for the possession of dangerous petroleum in receptacles containing more than 65 gallons, but not more than 2,000 gallons referred to in Rule 6 Chapter IV of Part II of the Petroleum Rules.

2. Correspondence ending with letter No. C² 147—28-29, dated 28th January 1929, from the Director of Industries and Commerce, stating that the special form "Q" introduced in Government Order dated 28th September 1926, does not answer the purpose in cases where the capacity of the tank is in excess of 2,000 gallons, and since cases had arisen in which licenses in excess of that quantity had been asked for, and suggesting certain amendments to the existing Rule 6 of Chapter IV to avoid inconvenience and to bring the rule in conformity with the one in force in British India.

ORDER NO. D. 10424-33—GEOL. 95-27-10, DATED 11TH APRIL 1929.

The limit of 2,000 gallons fixed in Rule 6 Chapter IV of the rules under Regulation I of 1923, leads to certain anomalies in practice, to avoid which, the Director of Industries and Commerce has recommended the adoption of a new form. But this expedient will not meet the case, and Government are of opinion that it is necessary to amend both Rule 6 and form "Q" in such wise as to render it possible to grant a special license under the amended rule in the same form for storing any reasonable quantity of dangerous petroleum in excess of 65 gallons. They are accordingly pleased to direct as follows:—

Rule 6 Chapter IV shall be amended by the omission of the words "but not more than 2,000 gallons each."

Notification amending Rule 6 Chapter IV, and revising form "Q" will be published separately.

N. RAMA RAO,
Secretary to Government,
Development Departments.

To—The Director of Industries and Commerce in Mysore.
The District Magistrates of Districts.
The Superintendent, Government Printing, for supplying the necessary forms to the Director of Industries and Commerce in Mysore.

Exd.—P. S. R. N.

W D 2919—GPB—635—16-4-29

Appendix F G—1

SUBJECT.....

.....

.....

Section Geol

File No. ~~39 28~~ 95/27

Serial No. 11

No. D 10434

Diary No. of letter replied to.....

General and Revenue Secretariat

( )

the *192*

~~To~~

..... Notified.

Date of issue 11/4/27

Signed by H. N. Lewander

In exercise of the powers conferred on ~~Govt.~~ them under Sec. 8 of the Mysore Petroleum Regn. I of 1923, the Govt. of H. H. the Maharaja of Mysore are pleased to direct that the following amendments be made to the rules issued under the Mysore Petroleum Regulation. The draft of ~~which~~ No amendments previously was published in the Mysore Gazette for general information.

List of enclosures.....

Copied by.....

Examined by.....

over

WD 0399—GPB—20,000—18-9-28

DEVELOPMENT SECRETARIAT.

No. D. 8575—*Geol.* 95-27-9, *dated* 21*st February* 1929.

In modification of Notification published on page 7, Part II, section 2 of the *Mysore Gazette*, dated the 3rd January 1929, with No. D. 6485—Geol. 95-27-7, dated the 21st December 1928, the following revised draft amendments which the Government propose to make in exercise of the powers conferred on them under section 8 of the Mysore Petroleum Regulation I of 1923 to the rules framed thereunder are hereby published for the information of the persons likely to be affected thereby, and notice is hereby given that the revised amendments will be taken into consideration on or after the 15th March 1929 and that suggestions or objections, if any, which may be received from any person with reference to the said amendments before the date aforesaid will be considered by Government.

AMENDMENTS.

(1) Rule 6, Chapter IV—Part II Omit the words "but not more than 2,000 gallons each."

(2) Form Q of the license form. "Revise the existing form and conditions to the form and conditions as hereto annexed."

By Order,
N. RAMA RAO,
Secretary to Government,
Development Departments.

FORM Q.

Special License to possess dangerous petroleum in one receptacle or more than one receptacle forming one unit and containing more than sixty-five gallons.
Rule 6, Chapter IV of Part II.

No. Fee Rs. eight

License is hereby granted to Messrs..... .. .. for the storage in the licensed premises described below of... ....gallons of dangerous petroleum in one tank subject to the rules for the storage of petroleum published in Notification No. I. C. 5415—Geol. 103-22-14, dated the 13th March 1924 as subsequently amended and to the further conditions attached hereto.

The.. ....192 .

Secretary to Government
or
the officer appointed by Government in this behalf.

(Description of the licensed premises above referred to.)

The licensed premises are situated at No..... ....and consist of a gas tight tank of a capacity of... ....gallons sunk underground.

CONDITIONS OF LICENSE.

1. Except when absolutely necessary for the purposes of condition 8, or for testing the accuracy of a pump's discharge by means of a standard capacity measure or when the tank and pump are erected completely inside a Dangerous Petroleum Installation, petroleum shall on no account be filled from the tank or pump or from a barrel of oil supplied by Petroleum Companies to be filled into the tank into any receptacle other than that clamped or fitted to a Motor Vehicle.

2. The petroleum shall be stored in one gas tight metal tank of a capacity of..... gallons sunk completely underground in the position shown on plan submitted, and placed in a pit lined with concrete or brick in cement, the tank being packed round with sand, earth or clay so that no air space is left below ground level and the tank is not visible.

3. A pump or pumps shall be placed in the position shown on plan submitted, the pipe connection between the tank and the pump or pumps shall be placed underground and all joints, valves and cocks shall be gas tight.

4. For the purpose of charging the tanks of locomotives the petroleum shall be:

(*a*) Pumped through strong metal piping by means of approved pumps into above-ground measuring tanks of a capacity not exceeding 30 gallons, fixed in approved positions, and run thence through sound hose, fitted with secure self-closing cock and nozzle into the tanks of locomotives, or

(*b*) pumped through strong metal piping by means of approved pumps into an above ground service tank of approved capacity, fixed in an approved position, and run-thence through strong metal piping into measuring tanks of a capacity not exceeding 30 gallons fixed in approved positions, and thence through sound hose, fitted with secure self-closing cock and nozzle, into the tanks of locomotives, or

(*c*) pumped by means of approved measuring pumps, fixed in approved positions, through sound hose, fitted with secure tap and nozzle, into the tanks of locomotives.

5. All tanks pumps, pipes and fittings shall be strongly constructed of the best materials.

6. The petroleum shall enter the tank "under seal" and all tanks shall be fitted with a vent pipe leading into the open air, the open end being covered with brass gauze 32 mes

and fitted with a hood or the open end shall be fitted with an inlet valve and on exhaust valve.

7. If the licensing officer call upon the holder of a license by a notice in writing, to execute any repairs to the storage premises, which may, in the opinion of such officer be necessary for the safety of the said premises, the holder of the license shall execute the repairs within such period, not being less than one month from the date of receipt of the notice as may be fixed by the notice.

8. The tank before being repaired shall be cleared of all dangerous petroleum and of all dangerous vapours arising from the same. When a tank in position is open for cleaning or repairs, no lamps of any description either ordinary, electric, electric torches or electric cables or electric fans shall be brought near the manhole of the tank (the inside of the tank may be lighted by the use of mirrors).

9. The license-holder is prohibited from delivering any quantity of dangerous petroleum exceeding three gallons to any one who has not a license under section 5 or section 6 of the Regulation.

10. All due precautions shall be taken for the prevention of unauthorised persons having access to any petroleum kept and to the vessels containing or having actually contained the same.

11. Every person managing or employed on or in connection with the storage premises shall abstain from any act whatever which tends to cause fire or explosion and which is not reasonably necessary and shall prevent any other person from doing such act. No fire or naked light shall be allowed to burn and no smoking or the lighting of any match shall be permitted within ten feet of a kerbside pump.

12. The storage premises shall be liable to inspection by an officer not being of lower rank than a Sub-Inspector of Police authorised by the Government in this behalf.

13. This license shall be held to cover the use of a portable kerbside pump outfit for a period of not more than one month in the place of the licensed permanent outfit in the event of the latter being out of order provided notice in writing is given to the Director of Industries and Commerce before the portable pump is taken into use.

By order

Asst to Govt.

Dev Deptt.

To

The Compiler Rupee Gazette

for publication in the

Gazette + with a request

that 50 copies of the notice

may be forwarded to this office

Rec'd D 10435 9/11/44

Copy forwarded to the Dir. of Ind.

for information

By order

Asst to Govt

Dev Deptt

DEVELOPMENT SECRETARIAT.

No. D. 10434—*Geol.* 93-27-15, *dated* 11*th April* 1929.

In exercise of the powers conferred on them under Section 8 of the Mysore Petroleum Regulation I of 1923, the Government of His Highness the Maharaja of Mysore are pleased to direct that the following amendments be made to the rules issued under the Mysore Petroleum Regulation. The draft of the amendments was previously published in the *Mysore Gazette* for general information.

AMENDMENTS.

(1) Rule 6, Chapter IV—Part II. Omit the words "but not more than 2,000 gallons each."

(2) Form Q of the license form. "Revise the existing form and conditions to the form and conditions as hereto annexed."

By Order,
N. RAMA RAO,
Secretary to Government,
Development Departments.

FORM Q.

Special License to possess dangerous petroleum in one receptacle or more than one receptacle forming one unit and containing more than sixty-five gallons.
Rule 6, Chapter IV of Part II.

No. Fee Rs. eight

License is hereby granted to Messrs..... for the storage in the licensed premises described below of.....gallons of dangercus petroleum in one tank subject to the rules for the storage of petroleum published in Notification No. I C. 5415—Geol. 103-22-14, dated the 13th March 1924 as subsequently amended and to the further conditions attached hereto.

The... .....192 Secretary to Government
or
the officer appointed by Government in this behalf.

(Description of the licensed premises above referred to)

The licensed premises are situated at No:..... .....and consist of a gas tight tank of a capacity of.....gallons sunk underground.

CONDITIONS OF LICENSE.

1 Except when absolutely necessary for the purposes of condition 8, or for testing the accuracy of a pump's discharge by means of a standard capacity measure or when the tank and pump are erected completely inside a Dangerous Petroleum Installation, petroleum shall on no account be filled from the tank or pump or from a barrel of oil supplied by Petroleum Companies to be filled into the tank into any receptacle other than that clamped or fitted to a Motor Vehicle.

2. The petroleum shall be stored in one gas tight metal tank of a capacity of..... gallons sunk completely underground in the position shown on plan submitted, and placed in a pit lined with concrete or brick in cement, the tank being packed round with sand, earth or clay so that no air space is left below ground level and the tank is not visible.

3. A pump or pumps shall be placed in the position shown on plan submitted, the pipe connection between the tank and the pump or pumps shall be placed underground and all joints, valves and cocks shall be gas tight.

4. For the purpose of charging the tanks of locomotives the petroleum shall be:

(*a*) Pumped through strong metal piping by means of approved pumps into above-ground measuring tanks of a capacity not exceeding 30 gallons, fixed in approved positions and run thence through sound hose, fitted with secure self-closing cock and nozzle into the tanks of locomotives, or

(*b*) pumped through strong metal piping by means of approved pumps into an above ground service tank of approved capacity, fixed in an approved position, and run thence through strong metal piping into measuring tanks of a capacity not exceeding 30 gallons fixed in approved positions, and thence through sound hose, fitted with secure self-closing cock and nozzle, into the tanks of locomotives, or

(*c*) pumped by means of approved measuring pumps, fixed in approved positions, through sound hose, fitted with secure tap and nozzle, into the tanks of locomotives,

5. All tanks pumps, pipes and fittings shall be strongly constructed of the best materials.

6. The petroleum shall enter the tank " under seal " and all tanks shall be fitted with a vent pipe leading into the open air, the open end being covered with brass gauze 32 mesh and fitted with a hood or the open end shall be fitted with an inlet valve and on exhaust valve.

7. If the licensing officer call upon the holder of a license by a notice in writing, to execute any repairs to the storage premises, which may, in the opinion of such officer be necessary for the safety of the said premises, the holder of the license shall execute the repairs within such period, not being less than one month from the date of receipt of the notice as may be fixed by the notice.

8. The tank before being repaired shall be cleared of all dangerous petroleum and of all dangerous vapours arising from the same. When a tank in position is open for cleaning or repairs, no lamps of any description either ordinary, electric, electric torches or electric cables or electric fans shall be brought near the manhole of the tank (the inside of the tank may be lighted by the use of mirrors).

9. The license-holder is prohibited from delivering any quantity of dangerous petroleum exceeding three gallons to anyone who has not a license under section 5 or section 6 of the Regulation.

10. All due precautions shall be taken for the prevention of unauthorised persons having access to any petroleum kept and to the vessels containing or having actually contained the same.

11. Every person managing or employed on or in connection with the storage premises shall abstain from any act whatever which tends to cause fire or explosion and which is not reasonably necessary and shall prevent any other person from doing such act. No fire or naked light shall be allowed to burn and no smoking or the lighting of any match shall be permitted within ten feet of a kerbside pump.

12. The storage premises shall be liable to inspection by an officer not being of lower rank than a Sub-Inspector of Police authorised by the Government in this behalf.

13. This license shall be held to cover the use of a portable kerbside pump outfit for a period of not more than one month in the place of the licensed permanent outfit in the event of the latter being out of order provided notice in writing is given to the Director of Industries and Commerce before the portable pump is taken into use.